

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-1591:110 Page 1 of 1

CATEGORY: Ionization Smoke Detectors

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Models 1220⁽¹⁾, 2420, 6249⁽¹⁾, 6250⁽¹⁾, 6250⁽¹⁾-100, 6250⁽¹⁾-200, 6264⁽¹⁾-001, 6264⁽¹⁾-100, and 6264⁽¹⁾-200 ionization type smoke detector heads. Refer to listee's data sheet for additional detailed model descriptions and operational considerations.

⁽¹⁾: Represent alpha character between A to Z except for C to classify market designator.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as ionization type smoke detector heads for use with separately listed compatible bases and fire alarm control units. Models 6249, 6264-001, and 1220 are suitable for releasing service.

NOTE: Formerly 7271-0073:113, 7256-0073:113 and 7271-1388:119

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager